

# SOURCE WATER ASSESSMENT REPORT

## AN EVALUATION OF THE SUSCEPTIBILITY OF PUBLIC DRINKING WATER SOURCES TO POTENTIAL CONTAMINATION

CT0320061

### Twin Hills Water District

The State of Connecticut Department of Public Health (DPH) in cooperation with the Department of Environmental Protection (DEP) recently completed an assessment of sources of public drinking water maintained and operated by Twin Hills Water District. This one-time assessment is part of a nationwide effort mandated by Congress under the Safe Drinking Water Act Amendments of 1996 to evaluate the susceptibility of all public drinking water sources in Connecticut to potential sources of contamination. DPH began working in partnership with the DEP in 1997 to develop Connecticut's Source Water Assessment Program, which was approved by the U.S. Environmental Protection Agency in 1999. Sources of potential contamination that are of concern to public drinking water supplies here in Connecticut are generally associated with historic waste disposal or commercial, industrial, agricultural and residential properties that store or use hazardous materials like petroleum products, solvents or agricultural chemicals.

The assessment is intended to provide Twin Hills Water District consumers with information about where their public drinking water comes from, sources of potential contamination that could impact it, and what can be done to help protect it. This assessment will also assist the public water supply system, regional planners, local government, public health officials and state agencies in evaluating the degree to which the three wells may be at risk from potential sources of contamination. The assessment can be used to target and implement enhanced source water protection measures such as routine inspections, protective land use regulations, acquisition of critical land, proper septic system maintenance, and public education. General sources of contamination with the potential to impact these wells include properties with underground fuel storage tanks, improperly maintained on-site septic systems, improper waste disposal, or commercial/industrial sites that store or use chemicals or generate hazardous wastes.

**ASSESSMENT METHODS.** The drinking water source assessment methods used by the Department of Public Health Drinking Water Division to evaluate the susceptibility of public drinking water sources to contamination are based on criteria individually tailored to surface water and groundwater sources. The criteria are keyed to sanitary conditions in the source water area, the presence of potential or historic sources of contamination, existing land use coverage's, and the need for additional source protection measures within the source water area. Source-specific data for community and non-community systems were used to determine whether a particular criterion should be rated as low, moderate or high, relative to the risk of potential contamination at the drinking water source. A ranking system was used to compute an average rank for each community drinking water source based on its environmental sensitivity, potential risk of contamination and source protection needs.

**ASSESSMENT RESULTS.** Individual assessment summaries and recommendations to enhance source protection for the public drinking water source(s) listed below are presented in the attachments.

Location	Name of Drinking Water Source(s)	Susceptibility Summary
Coventry	Well 1 & 2	Low

Additional information about drinking water quality and treatment for this source(s) is available in the Twin Hills Water District's annual Consumer Confidence Report.

The assessment of this source(s) and other comparable drinking water sources throughout Connecticut generally finds that adopting recommendations similar to those presented in the attachment(s) could reduce the susceptibility of most groundwater sources to potential sources of contamination.



Keeping Connecticut Healthy

State of Connecticut Department of Public Health  
Drinking Water Division

410 Capitol Avenue – MS# 51WAT  
P.O. Box 340308 Hartford, CT 06134  
(860) 509-7333

## SOURCE WATER ASSESSMENT SUMMARY

### Twin Hills Water District

Well Name	Well Location	Well Type	DEP Groundwater Classification	Source Water Area (acres)
Well 1	Coventry	Bedrock	GAA-Well	18

Factor	Source Water Assessment Ratings For This Well	Rating
<b>I</b>	<b>Environmental Sensitivity</b>	Low
<b>II</b>	<b>Potential Risk Factors</b>	Low
<b>III</b>	<b>Source Protection Need</b>	High
Overall Susceptibility to Potential Sources of Contamination		Low
This rating is intended to indicate susceptibility to potential sources of contamination that may be in the wellfield source water area and does not necessarily imply poor water quality.		

Assessment Factors		Initial Assessment Findings	Recommendations for Enhanced Source Protection
<b>I</b>	Contaminants Detected in Source Water	None	
<b>I</b>	General condition of well and related equipment	Good	Maintain well and equipment according to best management practices
<b>II</b>	DEP-inventoried Contaminant Release Points	There are no DEP-inventoried contaminant release points in this source water area	
<b>II</b>	Potential Sources of Contamination	There are no potential contaminant sources in this well's source water area	
<b>II</b>	Source Water Area Land Use In The Town Of: Coventry (Based on Satellite Imagery developed by University of Conn.)	Commercial/Industrial 0.00% Residential 22.19% Agricultural 39.33% Open or Undeveloped 38.47%	Proactively work with local officials and developers to insure that only low risk development occurs within the source water area. Support and encourage the acquisition of open space land within the source water area.
<b>III</b>	Land Area Around Wellhead	No information available	PWS should provide information about the amount of land it owns or controls within a 200 foot radius around this well
<b>III</b>	Local Aquifer Protection Regulations	Entire source water area is covered by local aquifer protection regulations	
<b>III</b>	Local Government Source Protection Initiatives	Drinking water source protection policies exist at the local governmental level	
<b>III</b>	Water System Source Protection Initiatives	No information available	PWS should provide information about basic practices employed to protect its drinking water sources



Keeping Connecticut Healthy

State of Connecticut Department of Public Health  
Drinking Water Division

410 Capitol Avenue – MS# 51WAT  
P.O. Box 340308 Hartford, CT 06134  
(860) 509-7333

## SOURCE WATER ASSESSMENT SUMMARY

### Twin Hills Water District

Well Name	Well Location	Well Type	DEP Groundwater Classification	Source Water Area (acres)
Well 2	Coventry	Bedrock	GAA-Well	36

Factor	Source Water Assessment Ratings For This Well	Rating
<b>I</b>	<b>Environmental Sensitivity</b>	Low
<b>II</b>	<b>Potential Risk Factors</b>	Low
<b>III</b>	<b>Source Protection Need</b>	High
Overall Susceptibility to Potential Sources of Contamination		Low
This rating is intended to indicate susceptibility to potential sources of contamination that may be in the wellfield source water area and does not necessarily imply poor water quality.		

Assessment Factors		Initial Assessment Findings	Recommendations for Enhanced Source Protection
<b>I</b>	Contaminants Detected in Source Water	None	
<b>I</b>	General condition of well and related equipment	Good	Maintain well and equipment according to best management practices
<b>II</b>	DEP-inventoried Contaminant Release Points	There are no DEP-inventoried contaminant release points in this source water area	
<b>II</b>	Potential Sources of Contamination	There are no potential contaminant sources in this well's source water area	
<b>II</b>	Source Water Area Land Use In The Town Of: Coventry <i>(Based on Satellite Imagery developed by University of Conn.)</i>	Commercial/Industrial 0.00% Residential 11.21% Agricultural 13.36% Open or Undeveloped 75.42%	Proactively work with local officials and developers to insure that only low risk development occurs within the source water area.  Support and encourage the acquisition of open space land within the source water area.
<b>III</b>	Land Area Around Wellhead	No information available	PWS should provide information about the amount of land it owns or controls within a 200 foot radius around this well
<b>III</b>	Local Aquifer Protection Regulations	Entire source water area is covered by local aquifer protection regulations	
<b>III</b>	Local Government Source Protection Initiatives	Drinking water source protection policies exist at the local governmental level	
<b>III</b>	Water System Source Protection Initiatives	No information available	PWS should provide information about basic practices employed to protect its drinking water sources

